



## **Ford Memorial Daycare Water Sampling Lead Analysis Report**

### **1. INTRODUCTION**

#### **1.1. GENERAL**

This report presents the results of our water sampling performed at the site of Ford Memorial Daycare, 16400 W. Warren, Detroit, MI., on May 16th, 2016. The sample results taken in conjunction with this investigation are also presented on Appendix 1.

#### **1.2. OBJECTIVES AND SCOPE**

In general, the objectives of this investigation were to:

Accurately evaluate water outlets for lead above the EPA Maximum Contaminate Level (MCL).

#### **1.3. AUTHORIZATION**

Authorization was provided by phone for our Professional Services by Brenda Bradford on April 29<sup>th</sup>, 2016.

### **2. SITE INVESTIGATIONS**

#### **2.1. FIELD PROGRAM**

In order to sample and evaluate water, GSES took six samples, a First Draw sample and a Flush sample, from three different locations on the site.

The field portion of our investigation was under control and continual supervision of an experienced member of our field scientist staff.

#### **2.2 LABORATORY TESTING**

##### **2.2.1. General**

In accordance with ASTM D3559 and the U.S. Environmental Protection Agency guidelines for lead in drinking water at schools and child care facilities, we took two samples: first draw and flush, which is the required testing standard for drinking water lead contamination.

Results of the tests indicate that the water is below the threshold for lead



contamination. A copy of the lab report and Chain of Custody is attached (Appendix 1).

### 3. DISCUSSIONS AND RECOMMENDATIONS

#### 3.1. DISCUSSIONS OF FINDINGS

The water results are below the threshold for lead contamination.

We appreciate the opportunity of providing this service for you. If you have any questions concerning this report or require additional information, please do not hesitate to contact the undersigned.

Respectfully submitted,

Michael Etters  
Field Scientist

Monica Starks, CIEC  
Principal

Council-certified Indoor Environmental  
Consultant Board-awarded by the  
American Council for Accredited  
Certification



Appendix 1, Lab Results, Chain of Custody

Laboratory ID: 0055

**National Testing Laboratories, Ltd**  
556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 355004**

**5/25/2016**

*16400 W. Warren*

**Customer:** G. S. Group  
Monica Starks  
17800 Woodward Ave  
#200  
Detroit, MI 48203

**Source:**

**Source City:**

**Source State:**

Ford Memorial Daycare, Sample  
1 Kitchen (First Draw)  
Detroit  
MI

**Date/Time Received:** 5/16/2016 14:00

**Collected by:** D. Hemphill

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	5/16/2016 07:05		5/20/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

**National Testing Laboratories, Ltd**  
556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 355005**

**5/25/2016**

**Customer:** G. S. Group  
Monica Starks  
17800 Woodward Ave  
#200  
Detroit, MI 48203

**Source:** Ford Memorial Daycare, Sample 2 Kitchen (Flush)  
**Source City:** Detroit  
**Source State:** MI

**Date/Time Received:** 5/16/2016 14:00

**Collected by:** D. Hemphill

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.015	mg/L	0.001	ND	1	5/16/2016 07:08		5/20/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

Laboratory ID: 0055

**National Testing Laboratories, Ltd**  
556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 355006**

**5/25/2016**

**Customer:** G. S. Group  
Monica Starks  
17800 Woodward Ave  
#200  
Detroit, MI 48203

**Source:** Ford Memorial Daycare, Sample  
3 Women's Bathroom (First  
Draw)  
**Source City:** Detroit  
**Source State:** MI

**Date/Time Received:** 5/16/2016 14:00

**Collected by:** D. Hemphill

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.015	mg/L	0.001	0.001	1	5/16/2016 07:11		5/20/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

Laboratory ID: 0055

**National Testing Laboratories, Ltd**  
556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 355007**

**5/25/2016**

**Customer:** G. S. Group  
Monica Starks  
17800 Woodward Ave  
#200  
Detroit, MI 48203

**Source:**

**Source City:**

**Source State:**

Ford Memorial Daycare, Sample  
4 Women's Bathroom (Flush)  
Detroit  
MI

**Date/Time Received:** 5/16/2016 14:00

**Collected by:** D. Hemphill

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.015	mg/L	0.001	0.001	1	5/16/2016 07:14		5/20/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

Laboratory ID: 0055

**National Testing Laboratories, Ltd**  
556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 355008**

**5/25/2016**

**Customer:** G. S. Group  
Monica Starks  
17800 Woodward Ave  
#200  
Detroit, MI 48203

**Source:** Ford Memorial Daycare, Sample  
5 Men's Bathroom (First Draw)  
**Source City:** Detroit  
**Source State:** MI

**Date/Time Received:** 5/16/2016 14:00

**Collected by:** D. Hemphill

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.015	mg/L	0.001	0.003	1	5/16/2016 07:17		5/20/2016

These test results may be used for compliance purpose as required.

Analyst	Tests
EC	200.8



James Abston, Operations Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

Laboratory ID: 0055

**National Testing Laboratories, Ltd**  
556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 355009**

**5/25/2016**

**Customer:** G. S. Group  
Monica Starks  
17800 Woodward Ave  
#200  
Detroit, MI 48203

**Source:** Ford Memorial Daycare, Sample  
6 Men's Bathroom (Flush)  
**Source City:** Detroit  
**Source State:** MI

**Date/Time Received:** 5/16/2016 14:00

**Collected by:** D. Hemphill

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.015	mg/L	0.001	0.001	1	5/16/2016 07:20		5/20/2016

These test results may be used for compliance purpose as required.


Analyst	Tests
EC	200.8



James Abston, Operations Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*





1-800-458-3330

## General Compliance

Order Number: 2076912

Order Date: 04/19/2016

Sample Number:

Product: Lead Only

Sample Paid: No Payment Method:

TSR: EF



Sold To:  
G. S. Group  
Monica Starks  
17800 Woodward Ave  
Detroit

MI 48203

Date Sampled: 5/16/16

Time Sampled: 0:205 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: ☒ EST ☐ CST ☐ MST ☐ PST

Client Name: Ford Memorial Daycare

Phone Number: 313-867-0500

Fax Number:

PWS ID# (if applicable):

Sample ID or Source: Sande Kitchen (First Draw)

Source Type: ☐ Spring ☐ Well ☒ Municipal ☐ Surface  
☐ Other:

City & State: Detroit, MI  
(If Different than Above)

Sample Collected By: Donnez Hemphill  
(Signature)

Sample Collected By: Donnez Hemphill  
(Please Print)

Form Completed By: Donnez Hemphill

Additional Comments:

### For Laboratory Use ONLY

Lab Accounting Information:

Payment \$:

Check #:

Lab Comments/Special Instructions:

State Forms:

Lab Sample Information:


Date Received: MAY 16 2016

Time Received: 14:00

Received By: [Signature]

- ☒ Sample receipt criteria checked & acceptable.  
☐ Deviations from acceptable sample receipt criteria noted on PSA form.

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS



1-800-458-3330

## General Compliance

Order Number: 2076912  
Order Date: 04/19/2016  
Sample Number:

355005



Product: Lead Only  
Sample Paid: No  
Payment Method:  
TSR: EF

Sold To:  
G. S. Group  
Monica Starks  
17800 Woodward Ave  
Detroit

MI 48203

Date Sampled : 05/16/16

Time Sampled: 0 : 708 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: ☒ EST ☐ CST ☐ MST ☐ PST

Client Name: Ford Memorial Daycare

Phone Number: 313-867-0500

Fax Number:

PWS ID# (if applicable):

Sample ID or Source: Sample 2 Kitchen (Flush)

Source Type: ☐ Spring ☐ Well ☒ Municipal ☐ Surface  
☐ Other:

City & State: Detroit, MI  
(If Different than Above)

Sample Collected By: Donnez Hemphill  
(Signature)

Sample Collected By: Donnez Hemphill  
(Please Print)

Form Completed By: Donnez Hemphill

Additional Comments:

### For Laboratory Use ONLY

Lab Accounting Information:

Payment \$:

Check #:

Lab Comments/Special Instructions:

State Forms:

Lab Sample Information:

Date Received: MAY 16/2016

Time Received: 14:00

Received By: [Signature]

☒ Sample receipt criteria checked & acceptable.

☐ Deviations from acceptable sample receipt criteria noted on PSA form.

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS



Quality Water Analysis

1-800-458-3330

## General Compliance

Order Number: 2076912

Order Date: 04/19/2016

Sample Number:

Product: Lead Only

Sample Paid: No Payment Method:

TSR: EF

355026



Sold To:

G. S. Group

Monica Starks

17800 Woodward Ave

Detroit

MI 48203

Date Sampled: 5/16/16

Time Sampled: 0:711 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: ☒ EST ☐ CST ☐ MST ☐ PST

Client Name: Ford Memorial Daycare

Phone Number: 313-867-0500

Fax Number:

PWS ID# (if applicable):

Sample ID or Source: Sample 3 Women's Bathroom (First Draw)

Source Type: ☐ Spring ☐ Well ☒ Municipal ☐ Surface  
☐ Other:

City & State: Detroit, MI  
(If Different than Above)

Sample Collected By: Donnez Hemphill  
(Signature)

Sample Collected By: Donnez Hemphill  
(Please Print)

Form Completed By: Donnez Hemphill

Additional Comments:

### For Laboratory Use ONLY

Lab Accounting Information:

Payment \$:

Check #:

Lab Comments/Special Instructions:

State Forms:

Lab Sample Information:

Date Received: MAY 16 2016

Time Received: 14:00

Received By: [Signature]

☒ Sample receipt criteria checked & acceptable.

☐ Deviations from acceptable sample receipt criteria noted on PSA form.

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS

**National Testing  
Laboratories, Ltd.**

*Quality Water Analysis*

1-800-458-3330

**General Compliance**

Order Number: 2076912

Order Date: 04/19/2016

Sample Number:

Product:

Lead Only

Sample Paid: No

Payment Method:

TSR: EF

355007



Sold To:

G. S. Group

Monica Starks

17800 Woodward Ave

Detroit

MI 48203

Date Sampled: 5/16/16

Time Sampled: 0:714 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: ☐ EST ☐ CST ☐ MST ☐ PST

Client Name: Ford Memorial Daycare

Phone Number: 313-867-0500

Fax Number: \_\_\_\_\_

PWS ID# (If applicable): \_\_\_\_\_

Sample ID or Source: Sample 4 Women's Bathroom (Flush)

Source Type: ☐ Spring ☐ Well ☒ Municipal ☐ Surface  
☐ Other: \_\_\_\_\_

City & State: Detroit, MI  
(If Different than Above)

Sample Collected By: Donnez Hemphill  
(Signature)

Sample Collected By: Donnez Hemphill  
(Please Print)

Form Completed By: Donnez Hemphill

Additional Comments:

**For Laboratory Use ONLY**

Lab Accounting Information:

Payment \$: \_\_\_\_\_

Check #: \_\_\_\_\_

Lab Comments/Special Instructions:

State Forms:

Lab Sample Information:

Date Received: MAY 16 2016

Time Received: 14:00

Received By: [Signature]

☒ Sample receipt criteria checked & acceptable.

☐ Deviations from acceptable sample receipt criteria noted on PSA form.

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS

**National Testing  
Laboratories, Ltd.**

*Quality Water Analysis*

1-800-458-3330

**General Compliance**

Order Number: 2076912

Order Date: 04/19/2016

Sample Number:

Product: Lead Only

Sample Paid: No Payment Method:

TSR: EF

355008



Sold To:  
G. S. Group  
Monica Starks  
17800 Woodward Ave  
Detroit

MI 48203

Date Sampled: 5/16/16

Time Sampled: 0:717 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: ☒ EST ☐ CST ☐ MST ☐ PST

Client Name: Ford Memorial Daycare

Phone Number: 313-867-0500

Fax Number: \_\_\_\_\_

PWS ID# (if applicable): \_\_\_\_\_

Sample ID or Source: Sample 5 Men's Bathroom (First Day)

Source Type: ☐ Spring ☐ Well ☒ Municipal ☐ Surface  
☐ Other: \_\_\_\_\_

City & State: Detroit, MI  
(If Different than Above)

Sample Collected By: Donnez Hemphill  
(Signature)

Sample Collected By: Donnez Hemphill  
(Please Print)

Form Completed By: Donnez Hemphill

Additional Comments:

**For Laboratory Use ONLY**

Lab Accounting Information:

Payment \$: \_\_\_\_\_

Check #: \_\_\_\_\_

Lab Comments/Special Instructions:

State Forms:

Lab Sample Information:

Date Received: MAY 16 2016


Time Received: 14:00

Received By: [Signature]

☒ Sample receipt criteria checked & acceptable.

☐ Deviations from acceptable sample receipt criteria noted on PSA form.

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS



1-800-458-3330

## General Compliance

Order Number: 2076912  
Order Date: 04/19/2016

355009

Sample Number:



Product: Lead Only

Sample Paid: No Payment Method:

TSR: EF

Sold To:  
G. S. Group  
Monica Starks  
17800 Woodward Ave  
Detroit

MI 48203

Date Sampled: 5/14/16

Time Sampled: 0:220 Please Use Military Time, e.g. 3:00pm = 15:00

Check Time Zone: ☒ EST ☐ CST ☐ MST ☐ PST

Client Name: Ford Memorial Daycare

Phone Number: 313-867-0500

Fax Number:

PWS ID# (if applicable):

Sample ID or Source: Sample 6 Men's bathroom (Flush)

Source Type: ☐ Spring ☐ Well ☒ Municipal ☐ Surface  
☐ Other:

City & State: Detroit, MI  
(If Different than Above)

Sample Collected By: Donnez Hemphill  
(Signature)

Sample Collected By: Donnez Hemphill  
(Please Print)

Form Completed By: Donnez Hemphill

Additional Comments:

### For Laboratory Use ONLY

Lab Accounting Information:

Payment \$:

Check #:

Lab Comments/Special Instructions:

State Forms:

Lab Sample Information:

Date Received: MAY 16, 2016

Time Received: 14:00

Received By: [Signature]

☒ Sample receipt criteria checked & acceptable.  
☐ Deviations from acceptable sample receipt criteria noted on PSA form.

INCOMPLETE INFORMATION MAY DELAY ANALYSIS AND/OR INVALIDATE RESULTS